


NB!
Chart data is aggregated by 1 h


Project Ivar Huitfeldtsvej, 4600 Køge
Project maintainer Jesper Haugaard
Customer NCC
Customer contact Petra Ghanem (+4546790101)
Time frame 2019-04-29 00:00 - 2019-05-05 23:59 (Europe/Copenhagen)
Measure point MP_1
Location Fændediget 10
Sensor type C22
Serial no. 101687
Master(s) serial no. 101687
Latest calibration 2018-10-09
Standard DIN4150-3 Anlage 25mm/s 1-315Hz
Unit mm/s
Quantity Velocity
Interval time 2 min
Frequency weighting OFF
Max V: 2.69 mm/s, L: 1.18 mm/s, T: 1.18 mm/s



X-span 2019-04-29 00:00:00 - 2019-05-05 23:59:00
Y-span V, L, T : mm/s: 0.0 - 5.0

	V	L	T
Max	2.69 mm/s	1.18 mm/s	1.18 mm/s
Date	2019-05-02	2019-05-02	2019-05-02
Time	10:00:00	10:00:00	13:00:00


Project Ivar Huitfeldtsvej, 4600 Køge
Project maintainer Jesper Haugaard
Customer NCC
Customer contact Petra Ghanem (+4546790101)
Time frame 2019-04-29 00:00 - 2019-05-05 23:59 (Europe/Copenhagen)
Measure point MP_2
Location Fændediget 12
Sensor type C22
Serial no. 101655
Master(s) serial no. 101655
Latest calibration 2018-10-09
Standard DIN4150-3 Anlage 25mm/s 1-315Hz
Unit mm/s
Quantity Velocity
Interval time 5 sec
Frequency weighting OFF
Max V: 3.67 mm/s, L: 3.53 mm/s, T: 3.89 mm/s



X-span 2019-04-29 00:00:00 - 2019-05-05 23:59:00
Y-span V, L, T : mm/s: 0.0 - 5.0

	V	L	T
Max	3.67 mm/s	3.53 mm/s	3.89 mm/s
Date	2019-05-02	2019-05-02	2019-05-02
Time	10:00:00	10:00:00	14:00:00

Project Ivar Huitfeldtsvej, 4600 Køge
Project maintainer Jesper Haugaard
Customer NCC
Customer contact Petra Ghanem (+4546790101)
Time frame 2019-04-29 00:00 - 2019-05-05 23:59 (Europe/Copenhagen)
Measure point MP_3
Location Åvænget 21
Sensor type C22
Serial no. 101681
Master(s) serial no. 101681
Latest calibration 2018-10-08
Standard DIN4150-3 Anlage 25mm/s 1-315Hz
Unit mm/s
Quantity Velocity
Interval time 2 min
Frequency weighting OFF
Max V: 0.57 mm/s, L: 0.47 mm/s, T: 1.020 mm/s



X-span 2019-04-29 00:00:00 - 2019-05-05 23:59:00


Y-span V, L, T : mm/s: 0.0 - 2.0

	V	L	T
Max	0.57 mm/s	0.47 mm/s	1.020 mm/s
Date	2019-05-04	2019-05-04	2019-05-04
Time	11:00:00	11:00:00	13:00:00

Project Ivar Huitfeldtsvej, 4600 Køge
Project maintainer Jesper Haugaard
Customer NCC
Customer contact Petra Ghanem (+4546790101)
Time frame 2019-04-29 00:00 - 2019-05-05 23:59 (Europe/Copenhagen)

Measure point MP_4
Location Toldbodvej 11
Sensor type C22
Serial no. 101683
Master(s) serial no. 101683
Latest calibration 2018-10-08
Standard DIN4150-3 Anlage 25mm/s 1-315Hz
Unit mm/s
Quantity Velocity
Interval time 5 sec
Frequency weighting OFF

Max V: 1.50 mm/s, L: 0.71 mm/s, T: 0.49 mm/s



X-span 2019-04-29 00:00:00 - 2019-05-05 23:59:00


Y-span V, L, T : mm/s: 0.0 - 2.0

	V	L	T
Max	1.50 mm/s	0.71 mm/s	0.49 mm/s
Date	2019-05-03	2019-05-02	2019-04-30
Time	08:00:00	10:00:00	16:00:00

Project Ivar Huitfeldtsvej, 4600 Køge
Project maintainer Jesper Haugaard
Customer NCC
Customer contact Petra Ghanem (+4546790101)
Time frame 2019-04-29 00:00 - 2019-05-05 23:59 (Europe/Copenhagen)

Measure point MP_5
Location Åvænget 29
Sensor type C22
Serial no. 101660
Master(s) serial no. 101660
Latest calibration 2018-10-09
Standard DIN4150-3 Anlage 25mm/s 1-315Hz
Unit mm/s
Quantity Velocity
Interval time 2 min
Frequency weighting OFF

Max V: 0.81 mm/s, L: 0.69 mm/s, T: 0.39 mm/s



X-span 2019-04-29 00:00:00 - 2019-05-05 23:59:00

Y-span V, L, T : mm/s: 0.0 - 1.0

	V	L	T
Max	0.81 mm/s	0.69 mm/s	0.39 mm/s
Date	2019-05-03	2019-05-03	2019-04-29
Time	18:00:00	18:00:00	20:00:00